

Kidde Fire Systems Component Description

Back-Plate Manifold Hoses

FEATURES

- For Approvals, see the “Compatibility” table.
- REACH and RoHS compliant

DESCRIPTION

Use the 27.6 in. (700mm) hose (P/N 01-3273-1200) to connect the back-plate manifold to the selector valves.

For Natura™ Inert gas systems, use the hose to connect the manifold to the pressure regulator on the back-plate manifold. For other clean agent systems, use this hose and adapter P/N: 85-025125-000 to connect a nitrogen pilot cylinder to the pressure regulator on the back-plate manifold.

This hose is included in discharge delay kits P/Ns 38-401140-030 and 38-401140-060 to connect the discharge delay to the Natura Inert gas system primary agent cylinder.

The hose has a nominal working pressure of 366 bar.



ORDERING INFORMATION

Part Number	Description
01-3273-1200	27.6 in. (700mm) Back-Plate Manifold Hose

COMPATIBILITY

Series	DIOM P/N	Approval
ECS-500™ System	06-237585-001	UL, ULC, FM
ADS™ with 3M™ Novec™ 1230 Fire Protection Fluid	06-237256-001	UL, ULC, FM
ECS™ 360 with 3M™ Novec™ 1230 Fire Protection Fluid	06-236553-001	UL, ULC, FM
ADS™ with HFC-227ea Agent	06-236068-001	UL, ULC, FM
ECS™ 360 with HFC-227ea Agent	06-236115-001	UL, ULC, FM
Natura™ Inert Gas System	06-237619-001	UL, FM
	06-237598-001	LPCB

EXPORT INFORMATION (USA)

Jurisdiction: EAR
Classification: EAR99
This document contains technical data subject to the EAR.

All trademarks are property of their respective owners.
©2022 Carrier

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. believes this data to be accurate, but it is published and presented without any guarantee or warranty whatsoever. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. Product features specified are only applicable when the fire suppression system is correctly designed, installed, maintained and serviced by trained, authorized Kidde Fire Systems distributors as per the applicable design, installation, operation, and maintenance manuals. If you need more information on this product, or if you have a particular problem or question, contact: KIDDE-FENWAL, INC., Ashland, MA 01721 USA, Telephone: (508) 881-2000.

Kidde Fire Systems
400 Main Street
Ashland, MA 01721
Ph: 508.881.2000
Fax: 508.881.8920
kiddefiresystems.com