

# Kidde Fire Systems

## ECS-500™ System

### Component Datasheet



Effective: December 2018  
K-45-0504 Rev AB



## Cylinder and Valve Assemblies, 350 lb. Capacity Cylinder

### FEATURES

- UL Listed, ULC Listed, and FM Approved for use with Kidde® ECS-500™ Systems (DIOM P/N 06-237585-001)
- UL Listed, ULC Listed and USCG Approved for use with Kidde® ECS-500™ Marine System (DIOM P/N 06237589-001)

P/N: 45-550351-001

### ORDER INFORMATION



Part Number	Description
45-550351-001	350 lb. Capacity Cylinder with Liquid Level Indicator

### MATERIALS

Valve Body: Brass  
Cylinder: Steel, Painted Red

### MANUALS

Manual	P/N
Kidde® ECS-500™ System	06-237585-001
Kidde® ECS-500™ Marine System	06-237589-001

### Note:

1. The safety cap must be installed on the valve outlet at all times, except when the cylinders are connected to the system piping, or being filled. The safety cap must not be removed from its chain.
2. See K-45-0513 for additional information.

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. believes this data to be accurate, but it is published and presented without any guarantee or warranty whatsoever. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. Product features specified are only applicable when the fire suppression system is correctly designed, installed, maintained and serviced by trained, authorized Kidde Fire Systems distributors as per the applicable design, installation, operation, and maintenance manuals. If you need more information on this product, or if you have a particular problem or question, contact: KIDDE-FENWAL, INC., Ashland, MA 01721 USA, Telephone: (508) 881-2000.

### EXPORT INFORMATION (USA)

Jurisdiction: EAR  
Classification: EAR99  
This document contains technical data subject to the EAR.

KIDDE is a registered trademark of Kidde-Fenwal, Inc., or its parents, subsidiaries or affiliates.  
©2018 Kidde-Fenwal, Inc.

Kidde Fire Systems  
400 Main Street  
Ashland, MA 01721  
Ph: 508.881.2000  
Fax: 508.881.8920  
[www.kiddefiresystems.com](http://www.kiddefiresystems.com)